

## Sarah Porter

---

**From:** Genevieve Reynolds [greynolds@primeengineering.org]  
**Sent:** Monday, October 01, 2018 1:17 PM  
**To:** Sarah Porter; Richard Rheaume  
**Subject:** RE: Bartlett Street

Hello Sarah:

See Rich's comments in italics.

Thanks,  
Genny

Rich, some other comments which have come up since the last hearing:

1. Why was only one side of the Bank of the stream flagged? Please have the other side flagged and surveyed.  
*Both banks are shown on the plan. The edge of BVW on the east side will be added.*
2. The NOI and plan do not indicate where the proposed subdivision is to be located.  
*There is no proposed subdivision at this time – perhaps never will be.*
3. The sewer easement goes through the wetland replication area. How deep is the sewer located underground and will the excavation of the wetland replication area impact the sewer line?  
*The sewer line is shown on the plans. There will be no impact to it.*
4. The plan view labels the proposed drive as a "20' wide paved drive" while the cross sections call it a "roadway".  
Please verify which is being proposed and modify the labels accordingly.  
*The "roadway" label has been changed to "drive".*

The DPI – Engineering department is also reviewing these plans and comments are forthcoming.

Please contact me if you should have any questions regarding these comments,

Thank you

Sarah Porter  
508-979-1497

---

**From:** Genevieve Reynolds [mailto:greynolds@primeengineering.org]  
**Sent:** Friday, September 28, 2018 11:06 AM  
**To:** Sarah Porter  
**Cc:** Richard Rheaume  
**Subject:** Bartlett Street

Hello Sarah:

On behalf of our client, Norman Nichols, please continue the hearing for Bartlett Street to your next meeting. I'm assuming that would be October 16?