



Department of Public Infrastructure

Ronald H. Labelle
Commissioner

Water
Wastewater
Highways
Engineering
Cemeteries
Park Maintenance

CITY OF NEW BEDFORD

Jonathan F. Mitchell, Mayor

MEMORANDUM

TO: City of New Bedford Planning Board
FROM: Ronald H. Labelle, Commissioner, D.P.I.
DATE: March 20, 2014
RE: Site Plan – Parking Lot
4499 Acushnet Avenue
Plot 137 Lot 171

The Department of Public Infrastructure has reviewed the proposed site plan referenced above and recommends approval with the following conditions:

1. Drainage design must comply with Phase II, Mass. Department stormwater Management standards.
2. Engineer must provide an explanation of where the runoff, not collected by the existing two catch basins, is being directed to.

/ct

Cc: Department of Inspectional Services
Environmental Stewardship
Thompson Farland
Meditrust of Massachusetts