



Conservation Commission
City of New Bedford
133 William Street, Room 304
New Bedford, MA 02740

**RE: Request for Administrative Alteration Approval
Map 136A Lot 884, Pequot Street SE049-0887**

Dear Commission Members,

We are requesting authorization for Administrative Alteration Approval of design changes made to the site plan approved under the order of conditions issued March 15, 2022, SE049-0887 for the above address. We have attached a copy of the plan approved under the OOC and the revised plan per DPI comments dated May 4, 2022.

After submittal of the building permit request we received comments from DPI. They requested that all impervious runoff be recharged on-site. Our office updated the plan by directing runoff from the proposed paved driveway to a lawn drain that leads to the subsurface recharge system in the rear of the lot. This increased the size of the system, but did not affect the proposed limit of work. The proposed concrete patio material was also changed to gravel. These changes to the plan decrease stormwater runoff.

We feel the changes to the design are minimal, are an improvement, and fall under the general scope of the order of conditions and can be approved administratively by the conservation agent. We appreciate your consideration of our request.

Very truly yours,

FARLAND CORPORATION, INC.

Christian A. Farland

Christian A. Farland, P.E., LEED AP
Principal Engineer and President